



Bureau de normalisation  
du Québec

BNQ is a member of the National  
Standards System (NSS).

# ANNEX TO THE CERTIFICATE

Page 1 of 1

**SUPERLIT BORU SAN S.A.**

Karaçali Mah. Düzce Cd. No:58  
81900 Kaynasli, Düzce  
TURKEY

**ASTM D3517/2019-08-01**

*Glass-Fiber-Reinforced Thermosetting-Resin Pressure Pipe*

Certificate number: **4114**  
Issue date: **2025-01-31**  
Expiry date: **2025-05-31**

DESCRIPTION			
Pipe Designation Code: D3517-1-1-1-C150-D, see note 1 below			
Nominal Pipe Size, mm	Nominal Pipe Size, mm	Nominal pressure class, psi	Minimum Pipe Stiffness, psi
DN, Ductile Iron Pipe Eq.	DN, international O.D.	PN C150	SN 72
400	-	Certified	Certified
500	-	Certified	Certified
600	-	Certified	Certified
-	700	Certified	Certified
-	800	Certified	Certified
-	900	Certified	Certified
-	1000	Certified	Certified
-	1100	Certified	Certified
-	1200	Certified	Certified
-	1500	Certified	Certified
-	1600	Certified	Certified

Note 1: GRP Joint Tightness has been verified with flexible (unrestrained coupling) and lock-joint (restrained coupling) for the maximum nominal working pressure class of PN C14,5, C87 et C150. Namely, "Full-Face® Flexible Coupling and Full-Face® Locked joint"

HISTORY	
Date	Modification description
2023-05-24	Issuance of certificate.
2023-06-19	Modification of the business name and address.
2024-12-05	Modification of the certificate: Addition of DN500, DN1100, DN1200PN; C150 psi, SN 72 psi.
2025-01-31	Modification of the certificate: Addition of DN400; C150 psi, SN 72 psi.

**THE ANNEX IS AN INTEGRAL PART OF THE CERTIFICATE.**